

INSTALLATION & MAINTENANCE INSTRUCTIONS

ELECTRONIC PRESSURE REGULATOR

DESCRIPTION / IDENTIFICATION

The QBX series valve uses the same Proportion-Air closed loop technology for Pressure control as the BB series. It gives an output pressure proportional to an input electrical command signal.

The QB1X is a complete closed loop system consisting of valves, manifold, housing and electronic controls. Pressure is controlled by the use of two solenoid valves. One valve functions as inlet control, the other as exhaust. The pressure output is measured by a pressure transducer internal to the QB1X and provides a feedback signal to the electronic controls. This feedback signal is compared with the command signal input. A difference between the two signals causes one of the solenoid valves to open, allowing flow in or out of the system. Accurate pressure is maintained by controlling these two valves.

The QB2X is similar to the QB1X but uses a double loop control scheme. In addition to the internal pressure transducer, the QB2X receives an electrical signal from an external sensing device. This primary feedback signal is compared against the command signal input. This comparison is then summed with the internal pressure transducer signal. The gain of the circuit is such that priority is given to the external feedback signal. A difference between the command signal and the feedback signal causes one of the solenoid valves to be activated.

A monitor output is provided for the system measurement. All QBX valves come standard with an analog voltage monitor output. QB1X monitor output is an amplified signal from the internal pressure transducer. QB2X monitor output is a buffered signal from the primary external transducer connected to the QB2X.

INSTALLATION

1. Apply a small amount of anaerobic sealant (provided) to the male threads of the in-line filter supplied with valve.

CAUTION: USE ONLY THE THREAD SEALANT PROVIDED. OTHER SEALANTS SUCH AS PTFE TAPE AND PIPE DOPE CAN MIGRATE INTO THE FLUID SYSTEM CAUSING FAILURES.

2. Install in-line filter to the INLET (I) port labeled I on QBX valve.
3. For vacuum or vacuum through positive pressure units, the vacuum supply should be connected to the exhaust port of the QBX.
4. Connect supply line to the in-line filter. Connect device being controlled to the OUTPUT (O) port labeled O on QBX valve.
5. For QBX, there are two output ports; one on the side of the manifold and one on bottom. The O port should be determined when ordering; check to ensure that the other port is plugged.
6. Mount valve accordingly.
7. The valve can be mounted in any position without affecting performance. Mounting bracket QBT-01 (ordered separately) can be used to attach valve to a panel or wall surface.
8. Proceed with electrical connections.



SPECIFICATIONS

ELECTRICAL

SUPPLY VOLTAGE	15-24 VDC
SUPPLY CURRENT	250 mA
COMMAND SIGNAL	0-10 VDC 4-20 mA
COMMAND SIGNAL IMPEDANCE	VDC=4.75 KΩ Current=100 Ω
ANALOGUE MONITOR SIGNAL	
VOLTAGE	0-10 VDC @ 20 mA max
CURRENT	4-20 mA Sinking or Sourcing

MECHANICAL

PRESSURE RANGES	Vacuum - 175 psig (760 mmHg (Vac) - 12 Bar)
OUTPUT PRESSURE†	0-100% of range
FLOW RATE	1.2 SCFM @ 100 psig inlet (34 L/min @ 6.89 Bar)
Min CLOSED END VOLUME	1 in ³
PORT SIZE	1/8" NPT
FILTRATION RECOMMENDED	40 Micron (included)
LINEARITY/HYSTERESIS	<±0.15% F.S. BFSL
REPEATABILITY	<±0.02% F.S.
ACCURACY	<±0.2% F.S.
WETTED PARTS ‡	
ELASTOMERS	Fluorocarbon
MANIFOLD	Aluminum
VALVES	Nickel Plated Brass
PRESSURE TRANSDUCER	Silicon, Ceramic Alumina

PHYSICAL

OPERATING TEMPERATURE	32-158°F (0-70°C)
WEIGHT	1.02 lb. (0.50 Kg)
PROTECTION RATING	IP65
HOUSING	Aluminum
FINISH	Black Anodized

† Pressure ranges are customer specified. Output pressures other than 100% are available. ‡ Others available


ELECTRICAL CONNECTIONS

1. Turn off all power to valve.
2. Identify the valve's command input and analog output using the calibration card included in the package and the ordering information section on the last page of this sheet.
3. Proceed to the appropriate section corresponding to the type of valve being installed.

NOTE: ALL COLOR CODES RELATE TO QBX'S ORDERED FROM THE FACTORY WITH WIRE LEADS.


COMMAND SIGNAL: E, I, K, V (WITH 3M CONNECTOR OPTION)

All voltage command QBTs use common mode voltage, meaning the DC Common pin is the common reference for both power and command. See below for a diagram of the proper command connections.




COMMAND SIGNAL: E, I, K, V (WITH 5M CONNECTOR OPTION)

See below for a diagram of the proper command connections for a 5M connector




MONITOR SIGNAL: E, K, V (AVAILABLE WITH 5M OPTION)

Use the following wiring diagram for QBX valves with a voltage monitor output.



MONITOR SIGNAL: C (AVAILABLE WITH 5M OPTION)

Use the following wiring diagram for QBX valves with a current monitor output.



RE-CALIBRATION PROCEDURE

All QBX control valves come calibrated from the factory by trained personnel using precision calibration equipment. The QBX valve is a closed loop control valve using a precision electronic pressure sensor. Typical drift is less than 1% over the life of the product. If your QBX valve appears to be out of calibration by more than 1%, it is not likely to be QBX. Check the system for plumbing leakage, wiring and electronic signal levels. Verify the accuracy of your measuring equipment before re-calibrating. Consult factory if you have any questions or require assistance. If the QBX valve needs re-calibration, use the procedure described below:

QB1X VALVES

1. Identify the inputs and outputs of the valve using the model number of the valve, calibration card included with the valve, and the information provided in this sheet.
2. Connect a precision measuring gage or pressure transducer to the OUT port of the QBX.
NOTE: THERE MUST BE A CLOSED VOLUME OF AT LEAST 1 CU. IN. (17 CC) BETWEEN THE VALVE OUTLET AND THE MEASURING DEVICE FOR THE VALVE TO BE STABLE.
3. Connect the correct supply source to the IN port of the QBX, making sure the pressure does not exceed the rating for the valve (See Table 1).
4. Locate the plastic calibration access cap on top of the QBX valve and completely remove it. Located underneath are two adjustment trim pots, Zero "Z" and Span "S". See figure 1 for pots location.
5. NOTE: Only use this step if your device is totally out of calibration. If it is slightly out of calibration, omit this step and move on to paragraph 6. Using a small screwdriver, turn both trim pots 15 turns clockwise. Then turn both potentiometers 7 turns counterclockwise. This will put the QBX roughly at mid-scale.
6. Make correct electrical connections as noted. Make sure there is a proper meter in place to measure the command input to the QBX.
7. Set the electrical command input to MAXIMUM value.
8. Adjust the SPAN pot until MAXIMUM desired pressure is reached (clockwise *increases* pressure).
9. Set the electrical command input to MINIMUM value.
10. Adjust the ZERO pot until MINIMUM desired pressure is reached (clockwise *increases* pressure).
11. Repeat ZERO and SPAN adjustments (steps 7-10) which interact slightly, until QB1 valve is calibrated back to proper range.
12. Replace calibration access cap.

QB2X VALVES

This section assumes there is a properly scaled and calibrated transducer for use as 2nd loop feedback signal.

1. Follow, in order, steps 1-5 as noted in the section titled QB1X VALVES .
2. Make correct electrical connections as noted. Make sure there is a proper meter in place to measure the command input to the QB2X. Make sure the 2nd loop signal is connected.
3. Set the electrical command input to MAXIMUM value.
4. Adjust the SPAN pot until MAXIMUM desired pressure is reached (clockwise *increases* pressure).
5. Set the electrical command input to MINIMUM value.
6. Adjust the ZERO pot until MINIMUM desired pressure is reached (clockwise *increases* pressure).
7. Repeat ZERO and SPAN adjustments, which interact slightly, until QB2X valve is calibrated back to proper range. Steps 3 - 6.
8. Replace calibration access cap.




FIGURE 1

QB2X SECOND LOOP CONNECTIONS

All QB2X valves are *designed to accept a 0-10 volt second loop input signal, unless ordered with special option code C2 (4-20 mA second loop input)*. Reference the following wiring diagrams for details.


QB2X-S305 option valves

Second loop signal is plugged into auxiliary receptacle on opposite side.




H23 COLOR CODE

Red/White	Signal In
Red/Black	Power
Green	Common



For valves ordered with a maximum calibrated pressure of:	Maximum rated inlet pressure is:
0 to 3 PSIG	CONSULT FACTORY
3.1 to 8 PSIG	20 PSIG
8.1 to 44.9 PSIG	60 PSIG
45 to 100.9 PSIG	110 PSIG
101 to 175PSIG	190 PSIG

TABLE 1



ACCURACY	±0.2% F.S.	PRESSURE	Full Vac to 175 PSIG (12 Bar)
PORT SIZE	1/8"	MAX FLOW	1.2 SCFM (34 SLPM)

Example Part Number

QB	2	X	A	N	E	E	N	1	P	6	BR	G	3D	TF
	1		2	3	4	5	6	7	8	9	10	11	OPTIONS	

Section Reference

1	Type	2	Manifold Material
1	Single Loop	A	Anodized Aluminum
2	Dual Loop	B	Brass*
*Includes O2 Cleaning			

3	Thread Type
N	NPT
P	BSPP

4	Input Signal Range
E	0 to 10 VDC
I	4 to 20 mA DC
K	0 to 5 VDC
V	1 to 5 VDC (Requires V for Monitor Signal #5)
D	0 to 255 Bit Digital (Cannot Select V for Monitor Signal #5)
L	0 to 255 Bit Digital Latching (Cannot Select V for Monitor Signal #5)
N	Ethernet/Proportion-Air (Requires X for Monitor Signal #5)
M	Ethernet/MODBUS TCP (Requires X for Monitor Signal #5)
A	RS232 Serial Input (Requires X for Monitor Signal #5)
B	RS485 Serial Input (Requires X for Monitor Signal #5)
P	P2 Profiler (Integrated)

5	Output Signal Range
X	No Monitor
E	0 to 10 VDC
K	0 to 5 VDC*
V	1 to 5 VDC*1
C	4 to 20 mA DC (Sinking)
S	4 to 20 mA DC (Sourcing)
*Requires E, I or K for Input Signal Range (#4)	
*1 Requires V for Input Signal Range (#4)	

6	Zero Offset
N	0% Pressure is Below Zero
P	0% Pressure is Above Zero
Z	0% Pressure is Zero (Typical)

7	Zero Offset Pressure
Typical is 0% - If greater than 30% of full scale pressure (#9 below), please consult factory.	
*If Z for Zero Offset, Please Leave this Section (#7) Blank	

8	Full Scale Pressure Type
N	100% Pressure is Below Zero
P	100% Pressure is Above Zero
Z	100% Pressure is Zero

9	Full Scale Pressure
Must be less than or equal to 175 psig	

10	Pressure Unit (no additional fee - all)		
PS	PSI	Inches Hg	IH
MB	Millibars	Inches H ₂ O	IW
BR	Bar	Millimeters H ₂ O	MW
KP	Kilo-pascal	Kilograms/cm ²	KG
MP	Mega-pascal	Torr (Requires A for Unit of Measure #11)	TR
MH	Millimeters Hg	Centimeters H ₂ O	CW
PA	Pascal		

11	Pressure Unit of Measure
A	Absolute Pressure
G	Gauge Pressure
D	Differential Pressure

Safety Precautions



Please read all of the following Safety Precautions before installing or operating any Proportion-Air, Inc. equipment or accessories. To confirm safety, be sure to observe 'ISO 4414: Pneumatic Fluid Power - General rules relating to systems' and other safety practices.



Warning

Improper operation could result in serious injury to persons or loss of life!

- PRODUCT COMPATIBILITY**
Proportion-Air, Inc. products and accessories are for use in industrial pneumatic applications with compressed air media. The compatibility of the equipment is the responsibility of the end user. Product performance and safety are the responsibility of the person who determined the compatibility of the system. Also, this person is responsible for continuously reviewing the suitability of the products specified for the system, referencing the latest catalog, installation manual, Safety Precautions and all materials related to the product.
- EMERGENCY SHUTOFF**
Proportion-Air, Inc. products cannot be used as an emergency shutoff. A redundant safety system should be installed in the system to prevent serious injury or loss of life.
- EXPLOSIVE ATMOSPHERES**
Products and equipment should not be used where harmful, corrosive or explosive materials or gases are present. Unless certified, Proportion-Air, Inc. products cannot be used with flammable gases or in hazardous environments.
- AIR QUALITY**
Clean, dry air is not required for Proportion-Air, Inc. products. However, a 40 micron particulate filter is recommended to prevent solid contamination from entering the product.
- TEMPERATURE**
Products should be used with a media and ambient environment inside of the specified temperature range of 32°F to 158°F. Consult factory for expanded temperature ranges.
- OPERATION**
Only trained and certified personnel should operate electronic and pneumatic machinery and equipment. Electronics and pneumatics are very dangerous when handled incorrectly. All industry standard safety guidelines should be observed.
- SERVICE AND MAINTENANCE**
Service and maintenance of machinery and equipment should only be handled by trained and experienced operators. Inspection should only be performed after safety has been confirmed. Ensure all supply pressure has been exhausted and residual energy (compressed gas, springs, gravity, etc.) has been released in the entire system prior to removing equipment for service or maintenance.



Caution

Improper operation could result in serious injury to persons or damages to equipment!

- PNEUMATIC CONNECTION**
All pipes, pneumatic hose and tubing should be free of all contamination, debris and chips prior to installation. Flush pipes with compressed air to remove any loose particles.
- THREAD SEALANT**
To prevent product contamination, thread tape is not recommended. Instead, a non-migrating thread sealant is recommended for installation. Apply sealant a couple threads from the end of the pipe thread to prevent contamination.
- ELECTRICAL CONNECTION**
To prevent electronic damage, all electrical specifications should be reviewed and all electrical connections should be verified prior to operation.

Exemption from Liability

- Proportion-Air, Inc. is exempted from any damages resulting from any operations not contained within the catalogs and/or instruction manuals and operations outside the range of its product specifications.
- Proportion-Air, Inc. is exempted from any damage or loss whatsoever caused by malfunctions of its products when combined with other devices or software.
- Proportion-Air, Inc. and its employees shall be exempted from any damage or loss resulting from earthquakes, fire, third person actions, accidents, intentional or unintentional operator error, product misapplication or irregular operating conditions.
- Proportion-Air, Inc. and its employees shall be exempted from any damage or loss, either direct or indirect, including consequential damage or loss, claims, proceedings, demands, costs, expenses, judgments, awards, loss of profits or loss of chance and any other liability whatsoever including legal expenses and costs, which may be suffered or incurred, whether in tort (including negligence), contract, breach of statutory duty, equity or otherwise.

Warranty

Proportion-Air, Inc. products are warranted to the original purchaser only against defects in material or workmanship for one (1) year from the date of manufacture. The extent of Proportion-Air's liability under this warranty is limited to repair or replacement of the defective unit at Proportion-Air's option. Proportion-Air shall have no liability under this warranty where improper installation or filtration occurred.